Building

Regulations Advisory Committee

Certificate of Accreditation

Amendment 2

Name of

INSULCON RAW PANEL EXTERNAL CLADDING SYSTEM

product:

product:

Product External wall cladding system

description:

Description of Suitable for use as a wall cladding system on Class 1 and 10, and Class 2 to 9 the purpose and buildings of Type 'C' construction only.

the purpose and use of the building

se of the

Regulation/s in relation to which the building product is accredited:

The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the Building Act 1993 has examined the application and accredited the Insulcon Raw Panel External Cladding System complies with the following Performance Requirements:

Volume One BP1.1, BP1.2 and Volume 2 P2.1.1, P2.2.2 of the Building Code of Australia as adopted by the *Building Regulations 2018*, to the extent that those clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the system, subject to the following conditions:

Conditions to which the accreditation is subject:

 The system must be installed on framing with stud spacing at a maximum of 600 mm centres and in accordance with the Insulcon Panels Installation Manual (Revision 5a, 29/08/2022), except that it must not be used in areas with a wind classification of more than N5 under AS 4055 and the maximum vertical fastener spacing (mm) must be as follows –

Stud	Location	Wind Classification to AS 40555					
spacing (mm)	(mm)	N1	N2	N3	N4	N5	
	Within 1200 of building edge	300	400	300	200	150	
450	elsewhere	600	600	600	400	250	
	Within 1200 of building edge	400	400	250	NS	NS	
600	elsewhere	600	600	400	300	200	



Building

Regulations Advisory Committee

- 2. The maximum installation height above ground level must not be more than 7 metres.
- 3. The product is only to be installed on timber and steel framework.
- 4. The fastenings must be in accordance with the following –

75mm Panels	40mm Panels	
10g x 100mm CSK Head	10g x 75mm CSK Head	
coarse ribbed Class 3	coarse ribbed Class 3	
Insulcon approved plastic		
	10g x 100mm CSK Head coarse ribbed Class 3	

- All fastenings must be protected against corrosion as set out in Table 3.3.5.4 of the Building Code of Australia 2019 (Amendment 1)
- 6. All fixtures and features attached to the wall must be secured into the wall
- 7. The product must only be used with breathable sarking behind the panels.
- 8. Render of the panels must be applied strictly in accordance with the render manufacturer's installation requirements. A minimum thickness of 5mm of render per coat must be applied to the external surface, with a minimum of 2 coats.

The name, address and Insulcon Pty Ltd 34 Swift Way

Australian

DANDENONG SOUTH VIC 3175

business

number of the holder of the

ABN 460 986 195 62

accreditation:

Certificate

V11/05-A2

number:

Date of issue: 10/10/2022

> Refer to the Historical Details page of this Certificate. This Certificate is only valid when reproduced in its entirety.

Date of expiry of accreditation:

10/10/2025

Signature:

Commissioner Yvonne von Hartel AM

Chair, Building Regulations Advisory Committee

Building

Regulations Advisory Committee

Practitioner guidance on how to use a Certificate of accreditation

Practitioners are reminded to consider any limitations noted in this Certificate and whether the performance of the product has been tested for all aspects of the performance that it is expected to achieve in the application it is being applied to.

Historical Details

Certificate number:	Description:	From:	То:
V11/05	Accreditation granted.	09/09/2011	-
V11/05-A1	Reissued on BRAC letterhead and signed by Chair. Updated references to Regulations.	01/07/2019	-
V11/05-A2	 Reaccreditation granted for a period of 3 years New certificate number issued Reference to product manual updated Updated reference to building regulations and Building Code of Australia Product description amended in response to the cladding ban under Section 192(1) of the Building Act 1993, that came into effect on 1 February 2021 Accreditation owner address updated 	10 October 2022	10 October 2025